

# STANDARDS UPDATE NOTICE (SUN) ISSUED: August 13, 2024

### **STANDARD INFORMATION**

Standard: UL 719

Standard ID: Nonmetallic-Sheathed Cables [UL 719:2015 Ed.13+R:07Nov2023]

Previous Standard ID: Nonmetallic-Sheathed Cables [UL 719:2015 Ed.13+R:12Jan2023]

#### **EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS**

Effective Date: November 7, 2025

#### IMPACT, OVERVIEW, AND ACTION REQUIRED

**Impact Statement:** Per our accreditation, Intertek is required to review reports against the standard revisions to confirm compliance. Once compliance is confirmed, the standard reference in the report is updated to show continued compliance to the technical requirements of the standard. Reports not updated to this version by the effective date above will be withdrawn.

**Overview of Changes:** NEC Related to Copper-Clad Aluminum. Specific details of new/revised requirements are found in table below.

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



## **STANDARD INFORMATION**

CLAUSE	VERDICT	COMMENT
		Additions to existing requirements are <u>underlined</u> and deletions are shown <del>lined out</del> below.
4	Info	Construction
4.3	Info	Conductors
4.3.1		Only soft-annealed copper, copper-clad aluminum, or an acceptable aluminum alloy shall be used for the conductor or conductors in a cable. Soft-annealed copper shall comply with ASTM B3. Solid aluminum conductors in size 12 – 8 AWG shall comply with the requirements for aluminum-wire stock (aluminum-alloy conductor material). All other aluminum conductors shall comply with the "Requirements for Aluminum Conductors of an 8000 Series Alloy", Section in the Reference Standard for Electrical Wires, Cables, and Flexible Cords, UL 1581. Copper-clad aluminum conductors shall comply with the "Requirements for Copper-Clad Aluminum Conductors" Used in Building Wire, Section 11 Section 12 in UL 1581. In a given cable, all conductors shall be of the same metal.